

Article IV- Subdivisions

Section 4.3.5 (c)(i)(7)

Maximum cut slope: ~~1~~ $1\frac{1}{2}$:1; maximum fill slope: ~~1~~ $\frac{1}{2}$:1. Steeper slopes may be permitted if certified by a professional engineer and approved by the Subdivision Ordinance Enforcement Officer. A bench with a minimum width of 5 feet shall be provided at the toe of all fill slopes greater than 10 feet in vertical height. All cut and fill slopes greater than 20 feet in vertical height shall have a bench with a minimum width of 5 feet for every 10 feet in vertical height. An illustration depicting the benching of cut and fill slopes is available on the County Planning Department website <https://www.planning.jacksonnc.org/> and from the Planning Department office.